

§ 134.180

(12) A list of shutdown locations for emergencies and guidance on restarting mechanical and electrical equipment and equipment for ventilation after shutdowns.

(13) A diagram of the hazardous locations (if applicable).

(14) A diagram of the emergency-power system.

(15) Stability information setting forth the maximum allowable height of the center of gravity in relation to draft data, displacement, and other applicable parameters unique to the design of the unit to determine compliance with the intact and damage stability criteria, under §§174.250 and 174.255 of this chapter.

46 CFR Ch. I (10–1–15 Edition)

(16) Curves of form as required under §170.075(a)(3) of this chapter.

§ 134.180 Piping for fire-main suction.

(a) Except as provided by paragraph (b) of this section, suction lines must comply with §132.110 of this subchapter.

(b) Suction lines that extend below the main deck outside the hull plating and that supply the fire pump with the liftboat in the elevated mode must be metallic, unless they comply with §56.60–25(c) of this chapter for vital fresh-water and salt-water service, except that they may be of unlimited length.

PARTS 135–139 [RESERVED]